

RIDER TES

THERMAL ENERGY STORAGE RIDER

APPLICABILITY

Applicable to customers who receive energy supply from the Company and who have installed a thermal storage cooling system and enter into a Service Agreement with the Company which will specify, among other terms and conditions, the kilowatt load to be shifted to the off peak period.

NET MONTHLY BILL

The Net Monthly Bill shall be computed in accordance with the provisions of the respective distribution service tariff, transmission service tariff, or as provided for by Rider LM, Load Management Rider.

BILLING DEMAND

The Company will utilize the actual demand established during the on peak period for monthly billing purposes. In the event the customer's equipment malfunctions during the off peak period and impacts the billing demand, an adjustment to the billing demand may be made, at the Company's discretion.

TERMS AND CONDITIONS

The off peak period for the summer season is defined as the period from 8:00 p.m. of one day to 11:00 a.m. of the following day; Friday from 8:00 p.m. to 11:00 a.m. of the following Monday; and from 8:00 p.m. of the day preceding a legal holiday to 11:00 a.m. of the day following that holiday. The following are recognized as legal holiday as far as load conditions of the Company's system are concerned: New Year's Day, President's Day, Good Friday, Memorial Day, Independence Day, Labor Day, Columbus Day, Veterans Day, Thanksgiving Day, Christmas or on the day nationally designated to be celebrated as such with the exception that if the foregoing holidays occur on a Sunday, the following Monday is considered a holiday. The summer period is defined as that period represented by the Company's billing for the four (4) revenue months of June through September.

A thermal storage cooling system is defined as a system utilizing heating, ventilating, and air conditioning (HVAC) equipment to accumulate energy in a body or system in the form of sensible heat (temperature rise) or latent heat (a change of phase). The stored energy is subsequently used to provide process cooling or space conditioning during the Company's on peak hours instead of operating traditional HVAC equipment.

Customer shall provide Company with access to customer's thermal storage cooling system for purposes of verifying that the system is well maintained and reliable.

The supplying of, and billing for, service and all conditions applying thereto are subject to the jurisdiction of the Public Utilities Commission of Ohio and to the Company's Service Regulations currently in effect and on file with the Public Utilities Commission of Ohio.

Filed pursuant to an Order dated March 29, 2006 in Case No. 06-407-GE-ATA before the Public Utilities Commission of Ohio.

Issued: March 31, 2006

Effective: April 3, 2006

Issued by Sandra P. Meyer, President