

# 603

REVISED 4/07

## SERVICE CONTACT BELOW THE ROOF LEVEL TO SERVICE-ENTRANCE CABLE

ONLY ONE SERVICE ATTACHMENT DEVICE IS REQUIRED FOR A TRIPLEX SERVICE DROP. THE TYPE OF SERVICE ATTACHMENT DEVICE IS SPECIFIED BY THE COMPANY. THE SERVICE ATTACHMENT DEVICE MUST BE SECURELY ATTACHED TO BUILDING STUDS OR OTHER PARTS OF THE BUILDING STRUCTURE. ALL SERVICE ATTACHMENT DEVICES ARE FURNISHED & INSTALLED BY THE CUSTOMER REFER TO 604 FOR SERVICE ATTACHMENT DEVICE INSTALLATION.

SERVICE-DROP AND FINAL CONNECTIONS INSTALLED BY THE COMPANY

SEE DRAWING 600 FOR CLEARANCE REQUIREMENTS

