

611

120/240V SINGLE PHASE METERING POLE (UP TO 400 AMPS MAX)

REVISED 4/07

INSTALLATION MUST CONFORM TO THE NATIONAL ELECTRIC CODE AND BE CERTIFIED BY THE LAWFULLY DESIGNATED ELECTRIC INSPECTOR FOR THE GEOGRAPHICAL AREA.

NOTES:

- 1) CUSTOMER TO CONTACT ENERGY DELIVERY FOR METER POLE LOCATION.
- 2) CUSTOMER TO DIG 5' DEEP POLE HOLE.
- 3) POLE AND HOLE MUST BE APPROVED BY POWER DELIVERY BEFORE POLE IS SET.
- 4) BACKFILL MUST BE SOLIDLY TAMPED WHEN POLE IS SET.
- 5) RAKING, KEYING, OR GUYING OF POLE MAY BE REQUIRED. CONTACT POWER DELIVERY FOR DETAILS.
- 6) CUSTOMER TO FURNISH AND INSTALL ALL MATERIALS.

* METERING POLE LOCATION HEIGHT, CLASS, DEPTH OF SETTING AND GUYING MUST BE APPROVED BY ENERGY DELIVERY. DEPTH OF THE HOLE MUST BE CHECKED BY THE COMPANY BEFORE THE POLE IS SET. (SEE ARTICLE 501C)

