

### **SECTION III - CUSTOMER'S INSTALLATION**

1. Nature and Use of Installation.

All equipment in the premises or connecting the premises with Company's service, furnished by the Customer, shall be suitable for the purposes thereof, and shall be maintained by Customer at all times in conformity with the safety requirements of the accredited agency having jurisdiction and with the rules, regulations and requirements of Company in force from time to time.

2. Materials - Fittings - Tests.

The piping and fittings for the distribution of gas after it has passed the meter, may be installed by any competent gas fitter employed by the customer or proprietor of the premises, subject, however, to the inspection and approval of the Company which requires an inspection and test of all such piping.

An application for inspection and test must be made to the Company when the piping work has been completed, but prior to its concealment by plastering, flooring or other materials.

3. Construction.

All piping shall be installed in accordance with applicable building codes and the rules and regulations of the Company.

4. Changes in Installations.

As Company's facilities used in supplying service to Customer have a limited capacity, Customer should give notice to Company, and obtain Company's consent, before making any material changes or increases in his installation. Company as promptly as possible after receipt of such notice will give its written approval to the proposed change or increase, or will advise Customer upon what conditions service can be supplied for such change or increase.

---

Issued by authority of an Order of the Kentucky Public Service Commission dated December 29, 2009 in Case No. 2009-00202.

---

Issued: September 29, 2010

Effective: September 30, 2010

Issued by Julie Janson, President